

Remote/Virtual Inspection Checklist

All of the stated requirements must be fulfilled, and the required items must be performed or provided via video or photo and submitted for review to the District prior to closing the installation and completing the job. Failure to provide advance notification and submissions will require the reopening of the installation for visual inspection at a later date, and the installation will be failed on inspection until a re-inspection is possible.

The installing contractor must;

- Take clear pictures of the wye/tee connection, cleanout, check valve and the address of the property of sufficient quality and detail that verification of proper installation and appropriate materials is possible.
- Measure and report the depth at connection the sewer main from the top of pipe to asphalt. Take a picture of the measuring tape reading at the asphalt.
- Measure and report the distance from face of curb to the mainline connection.
- Provide proof of installation of two-way cleanouts as required.
- Provide proof of installation of the check valve as required.
- Measure, report and provide visual documentation of the depth of clean-out and check valve from rim of cover to top of pipe. Typically 12" minimum is required for these installations.
- Take and provide one continuous video of the new lateral showing the residents address as well as the distance reading in feet from cleanout to sewer main and the connection at the main.
- Drain Rock is required, and a 6 inch minimum depth below and above the lateral is required.
- Class II AB is the standard acceptable to the District.
- No ABS pipe is allowed in any installation, and use of this material will result in a failed inspection and the requirement to replace this material with materials acceptable to the District under the Code.

The Contractor must Email proof and documentation of all finished work before backfilling any project. Send emails to District Inspector Otis Ward at oward@wcvd.org.

If you have any questions about this process or these requirements, please call the District Inspector @ 510-815-4926.